

Parámetros de Calidad de Gas a introducir en los conversores PTZ durante el Segundo Semestre de 2022



Posición Position	PCS SCV kWh/m3 (n)	PCI ICV kWh/m3 (n)	Densidad Density	N2 % mol	CO2 % mol	Variación PCS %
12	11,626	10,471	0,589	0,159	0,092	-1,02%
12EM	11,626	10,471	0,589	0,159	0,092	-1,02%
13	11,626	10,471	0,589	0,159	0,092	-1,08%
14	11,626	10,471	0,589	0,159	0,092	-1,02%
ERP07-01	11,626	10,471	0,589	0,159	0,092	-1,02%
13A	11,616	10,462	0,589	0,184	0,124	-1,16%
15.11	11,572	10,420	0,584	0,094	0,002	-2,27%
15.11-01	11,572	10,420	0,584	0,094	0,002	-2,27%
15.11ENA	11,572	10,420	0,584	0,094	0,002	-2,27%
15.11SAG	11,572	10,420	0,584	0,094	0,002	-2,27%
CC.SG.UF	11,572	10,420	0,584	0,094	0,002	-2,27%
15.34.3	11,626	10,470	0,587	0,130	0,000	-2,10%
15.34.31	11,626	10,470	0,587	0,130	0,000	-2,10%
CC.CG.IB	11,626	10,470	0,587	0,130	0,000	-2,10%
1D	11,621	10,466	0,587	0,161	0,000	-1,35%
20B	11,578	10,427	0,588	0,194	0,152	-1,42%
38	11,504	10,358	0,584	0,228	0,157	-1,21%
38X.01	11,495	10,349	0,583	0,229	0,158	-1,22%
38X.02	11,495	10,349	0,583	0,229	0,158	-1,22%
39.01	11,495	10,349	0,583	0,229	0,158	-1,29%
40	11,495	10,349	0,583	0,229	0,158	-1,29%
4	11,656	10,499	0,589	0,142	0,006	-1,07%
4.03	11,648	10,491	0,589	0,143	0,008	-1,10%
4.07.36	11,648	10,491	0,589	0,143	0,008	-1,10%
4.07.45	11,648	10,491	0,589	0,143	0,008	-1,10%
5D.04	11,648	10,491	0,589	0,143	0,008	-1,10%
5D.06	11,648	10,491	0,589	0,143	0,008	-1,10%
ERP01-01	11,648	10,491	0,589	0,143	0,008	-1,10%
41.01	11,511	10,364	0,584	0,242	0,150	-1,26%
41.02	11,512	10,366	0,584	0,247	0,154	-1,25%
41.03	11,512	10,366	0,585	0,247	0,154	-1,25%
41.03X01	11,512	10,366	0,585	0,247	0,154	-1,26%
41.04	11,519	10,372	0,586	0,274	0,171	-1,19%
41.05	11,519	10,372	0,586	0,274	0,171	-1,19%
41.06	11,519	10,372	0,586	0,274	0,171	-1,19%
41.06.01	11,519	10,372	0,585	0,271	0,164	-1,19%
41.07X	11,519	10,372	0,586	0,274	0,171	-1,19%
41.07X01	11,520	10,373	0,585	0,270	0,164	-1,19%
41.08	11,520	10,373	0,585	0,270	0,164	-1,19%
41.09	11,520	10,373	0,585	0,270	0,164	-1,19%
41.10	11,520	10,373	0,585	0,270	0,164	-1,19%
41.10.01	11,520	10,373	0,585	0,270	0,164	-1,19%
41-16	11,504	10,358	0,583	0,219	0,136	-1,32%
41-72	11,504	10,358	0,583	0,219	0,136	-1,32%
41.ENA	11,504	10,358	0,583	0,219	0,136	-1,32%
41B	11,504	10,358	0,583	0,219	0,136	-1,32%
43X.00	11,479	10,334	0,580	0,161	0,031	-1,14%
10	11,639	10,483	0,590	0,174	0,054	-1,01%
9.02	11,639	10,483	0,590	0,174	0,054	-1,01%
9.03	11,639	10,483	0,590	0,174	0,054	-1,01%
9.05	11,639	10,483	0,590	0,174	0,054	-1,01%
I015.REG	11,738	10,574	0,594	0,096	0,006	1,30%
B35X	11,650	10,505	0,589	0,148	0,001	-1,20%
ERPA36-01	11,650	10,505	0,589	0,148	0,001	-1,20%
1.01	11,651	10,501	0,589	0,147	0,000	-1,17%
CC.CG.AE	11,615	10,460	0,587	0,108	0,003	-2,11%
CC.CG.GN	11,634	10,478	0,588	0,111	0,005	-2,05%
D07.01	11,509	10,362	0,584	0,185	0,146	-1,60%
D08A	11,566	10,416	0,593	0,329	0,402	-1,19%
D10A	11,566	10,416	0,593	0,329	0,402	-1,19%
F00-C	11,617	10,462	0,587	0,119	0,000	-1,77%
F00-D	11,617	10,462	0,587	0,119	0,000	-1,77%
F00C11	11,617	10,462	0,587	0,119	0,000	-1,77%

Parámetros de Calidad de Gas a introducir en los conversores PTZ durante el Segundo Semestre de 2022



Posición Position	PCS SCV kWh/m3 (n)	PCI ICV kWh/m3 (n)	Densidad Density	N2 % mol	CO2 % mol	Variación PCS %
CC.PF.E	11,614	10,459	0,587	0,152	0,000	-1,79%
CC.PF.UF	11,614	10,459	0,587	0,152	0,000	-1,79%
F02.1	11,614	10,459	0,587	0,152	0,000	-1,79%
F02.2	11,614	10,459	0,587	0,152	0,000	-1,79%
F02X-A	11,614	10,459	0,587	0,152	0,000	-1,79%
F02X-B	11,614	10,459	0,587	0,152	0,000	-1,79%
F03A.1	11,483	10,338	0,581	0,293	0,015	4,19%
F06	11,424	10,287	0,590	1,160	0,197	-1,20%
F06.2	11,620	10,465	0,587	0,113	0,000	-1,72%
F07	11,620	10,465	0,587	0,113	0,000	-1,72%
F07.01	11,620	10,465	0,587	0,113	0,000	-1,72%
F07.04	11,620	10,465	0,587	0,113	0,000	-1,72%
F08	11,620	10,465	0,587	0,113	0,000	-1,72%
F09	11,620	10,465	0,587	0,113	0,000	-1,72%
F11	11,620	10,466	0,588	0,156	0,058	-1,76%
F11-01	11,620	10,466	0,588	0,156	0,058	-1,76%
F13	11,620	10,466	0,588	0,156	0,058	-1,76%
I013.ENA	11,702	10,561	0,592	0,097	0,000	1,27%
H00	11,626	10,470	0,588	0,132	0,000	-2,10%
H16X	11,618	10,463	0,587	0,119	0,000	-1,76%
H72N	11,616	10,462	0,587	0,120	0,000	-1,77%
K01.MAR	11,481	10,346	0,618	1,624	1,411	1,00%
CC.SR.E	11,591	10,446	0,616	0,853	1,427	1,03%
CC.SR.GN	11,591	10,446	0,616	0,853	1,427	1,03%
CC.SR.PM	11,591	10,446	0,616	0,853	1,427	1,03%
CC.SR.UF	11,591	10,446	0,616	0,853	1,427	1,03%
K01.1	11,591	10,446	0,616	0,853	1,427	1,00%
K02-A	11,591	10,446	0,616	0,853	1,427	1,03%
K02-ALGE	11,591	10,446	0,616	0,853	1,427	1,03%
K02-B	11,591	10,446	0,616	0,853	1,427	1,03%
K02-C	11,591	10,446	0,616	0,853	1,427	1,03%
K02-E	11,591	10,446	0,616	0,853	1,427	1,03%
K02-F	11,591	10,446	0,616	0,853	1,427	1,03%
K02.02-E	11,591	10,446	0,616	0,853	1,427	-1,04%
K02.02A	11,591	10,446	0,616	0,853	1,427	1,03%
K02.03B	11,591	10,446	0,616	0,853	1,427	1,03%
K02031A1	11,591	10,446	0,616	0,853	1,427	1,03%
K05	11,591	10,446	0,616	0,853	1,427	1,03%
K07	11,591	10,446	0,616	0,853	1,427	1,03%
K02.031A	11,597	10,452	0,616	0,811	1,430	1,04%
K11.01	11,595	10,450	0,616	0,823	1,444	1,00%
K11.10	11,595	10,450	0,616	0,823	1,444	1,00%
K11.2	11,595	10,450	0,616	0,823	1,444	1,00%
K11.2.1	11,595	10,450	0,616	0,823	1,444	1,00%
K11.2.1E	11,595	10,450	0,616	0,823	1,444	1,00%
K19	11,595	10,450	0,616	0,823	1,444	1,00%
M00	11,594	10,451	0,623	0,972	1,757	-1,09%
M01	11,594	10,451	0,623	0,972	1,757	-1,09%
M05	11,594	10,451	0,623	0,972	1,757	-1,00%
M05EGT	11,594	10,451	0,623	0,972	1,757	-1,00%
M09	11,594	10,451	0,623	0,972	1,757	-1,11%
M09RGT	11,594	10,451	0,623	0,972	1,757	-1,00%
O3A	11,671	10,512	0,590	0,107	0,001	1,01%
O4B.1	11,671	10,512	0,590	0,107	0,001	1,01%
O5B.1	11,671	10,512	0,590	0,107	0,001	1,01%
S06.01	11,592	10,447	0,617	0,858	1,468	1,03%
S06.02	11,592	10,447	0,617	0,858	1,468	1,03%
S06.04	11,592	10,447	0,617	0,858	1,468	1,03%
S06.06	11,592	10,447	0,617	0,858	1,468	1,03%
S07	11,592	10,447	0,617	0,858	1,468	1,03%
S08	11,592	10,447	0,617	0,858	1,468	1,03%
S08.01	11,592	10,447	0,617	0,858	1,468	1,03%
S08.03	11,592	10,447	0,617	0,858	1,468	1,03%
B07.07X	11,614	10,463	0,599	0,419	0,560	-1,12%
V01	11,614	10,463	0,599	0,419	0,560	-1,12%